

SHEET NOTES:

- ALL CHILLED WATER PIPING 3" AND SMALLER AND HEATING HOT WATER PIPING SHALL BE TYPE L COPPER.

  ALL CHILLED WATER PIPING 4" AND LARGER WILL BE SCHEDULE 40 STEEL WITH VICTALIC FITTINGS.
- ALL CHILLED AND HEATING HOT WATER PIPING SHALL BEINSULATED PER THE REQUIREMENTS OF TITLE 24. PROVIDE PROTECTIVE COATING FOR PIPE INSULATION IN EQUIPMENT ROOMS.

IDENTIFICATION STAMP DIVISION OF THE STATE ARCHITECT APPL. 01-



Revision Description

Date

Revision Description


M2-04P

College of San Mateo Building 5N

DSA Submittal San Mateo, CA

Developed for

College of San Mateo



WESTERN ALLIED
MECHANICAL INC
MECHANICAL CONTRACTORS