


GENERAL NOTES (FIRE ALARM SITE PLAN)

- 1. THERE SHALL BE NO UNDERGROUND SPLICES, UNLESS OTHERWISE NOTED.
- 2. LABEL IN GRADE FIRE ALARM PULL BOXES AS "FIRE ALARM."
- 3. CONCEAL ALL CONDUIT, UNLESS OTHERWISE NOTED.
- 4. ALL EXTERIOR UNDERGROUND FIRE ALARM CONDUIT SHALL BE 2", UNLESS OTHERWISE
- 5. AREA MAY CONTAIN UNDERGROUND RACEWAY. SITE LOCATE ALL EXISTING UNDERGROUND RACEWAY IN AREA BEFORE TRENCHING. MAINTAIN EXTREME CARE WHEN TRENCHING.

SHEET NOTES

TRI-B6M NOT BE MOUNTED IN ATTIC SPACE. IT MUST BE MOUNTED BELOW CEILING.





THE DRAWING AND DESIGN HEREIN SHALL NOT BE DUPLICATED, USED OR DISCLOSED TO OTHERS FOR PROCUREMENT OR OTHER PURPOSE (EXCEPT AS OTHERWISE AUTHORIZED BY CONTRACT) WITHOUT WRITTEN PERMISSION OF SIEMENS BUILDING TECHNOLOGIES, INC.. FIRE SAFETY DIVISION. ALL OTHER REPRODUCTIONS SHALL BEAR THIS NOTICE.

REVISIONS



3140 De La Cruz Boulevard, Suite 110 Santa Clara, California 95054 tel: (408) 562-3560, fax: (408) 562-3561

CONTRACTOR'S NAME & ADDRESS:

CUPERTINO ELECTRIC

1132 N. Seventh Street San Jose, CA 95112

> TEL (408) 808-8135 FAX (408) 279-4605

California State C10 License No. 174637

SIEMENS

Building Technologies, Inc. Fire Safety Division

25821 Industrial Boulevard, Suite 300 Hayward, California 94545-2991

California State C10 License No. 758796 U.L. Certificate ID No. 324787-001 JOB NAME & LOCATION (STREET ADDRESS)

CANADA COLLEGE

4200 FARM HILL BLVD. REDWOOD CITY, CA 94061

ATHLETIC FIELD PROJECT MODULAR BUILDINGS

FIRE ALARM PLAN MULTI-USE BUILDING

☑ NEW INSTALLATION □ DESIGN/BUILD ☑ PER CONTRACT DOCUMENT

L.B.Terrado AS NOTED

10-9084

NOTE: HIGHLIGHTED ITEMS APPLY TO NEW SCOPE OF WORK and FADED ITEMS ARE EXISTING SHOWN FOR REFERENCE ONLY.