

SECTION 22 05 29  
HANGERS AND SUPPORTS FOR PLUMBING, PIPING, AND EQUIPMENT  
Design Standard

PART 1 GENERAL

1.1 PURPOSE:

The plumbing piping and equipment hangers are an essential element of the plumbing systems. This design standard has the purpose of creating a consistent application of plumbing piping and equipment hanger requirements throughout the San Mateo County Community College District. The intent is to create a standard of quality for maintenance, reliability throughout all renovation and new building projects.

PART 2 PRODUCT

Design and specify work to include material and installation of supports, anchors and sleeves including: horizontal piping hangers and supports; vertical piping clamps; hanger rod attachments; building attachments; saddles and shields; miscellaneous metals; miscellaneous materials; roof equipment supports; anchors; equipment supports; wall and floor sleeves; and escutcheon plates for a complete and operable systems.

- A. Materials, design and manufacture of all pipe hangers and supports to comply with MSS SP 58, "Pipe Hangers and Supports Materials, Design and Manufacture," latest edition.
- B. Select and apply pipe hangers and supports complying with MSS SP 69, "Pipe Hangers and Supports Selection and Application," latest edition. Use only one type by one manufacturer for each piping service. Select size of hangers and supports to exactly fit pipe size for bare piping, and to exactly fit around piping insulation with saddle or shield for insulated piping. Provide copper plated hangers and supports for un-insulated copper piping systems.
  - 1. Pipe Hangers Size 2 Inches and Smaller: Adjustable swivel ring hanger, UL listed
  - 2. Pipe Hangers Size 2 1/2 Inches and Larger: Adjustable clevis type, UL listed
- C. The use of pipe hooks, chains, plumbers tape, or perforated iron for pipe supports is not acceptable.
- D. All piping shall be designed to maintain the required pitch and shall provide for proper expansion and contraction.
- E. Vertical runs of pipe shall be supported with steel, UL listed riser clamps made specifically for pipe or for tubing.
- F. Due to the harsh outdoor environment at Skyline College (heavy salt laden ocean fog), all piping supports at Skyline College that are in contact with the outdoor air shall be protected against corrosion.
- G. Piping supports shall be designed to withstand seismic forces.
- H. Roof equipment supports: Coordinate the location and type of each roof equipment support with the roofing system supplier. Coordinate systems to maintain roof warranty. Regarding all supports exposed to the outdoor environment, see comment above, regarding SMCCCD's concern for corrosion protection at Skyline College.
  - 1. Compensate for slope in roof so top of support and roof mounted equipment is kept level.

2. Construct curb to withstand seismic forces.
- I. Roof Pipe Supports: Support piping on roof with polyethylene high-density U.V. resistant quick "pipe" block with foam pad. Recommended installation is for quick "pipe" blocks to be freestanding. Piping 3 inch and larger mounted on roller hangers. Wood block supports are not acceptable due to increased maintenance and low reliability.
- J. Escutcheon Plates: Design around horizontal and vertical piping at visible penetrations through walls, partitions, floors, or ceilings, including penetrations through closets, through below ceiling corridor walls, and through equipment room walls and floors.

## 2.2 APPROVED MANUFACTURERS:

- A. Pipe Hanger Supports:
  1. B-Line
  2. Michigan
  3. Superstrut
  4. Unistrut
- B. Roof Equipment Supports:
  1. Pate ES
  2. Custom Curb
  3. Vibrex
  4. Thycurb
- C. Roof Pipe Supports:
  1. Erico Pipe Piers
  2. Nelson-Olsen Inc.

## PART 3 EXECUTION

### 3.1 SUBSTITUTES ALLOWED?

Yes, if performance and quality equivalency can be evidenced.

### 3.2 ASSOCIATED DESIGN STANDARDS AND CONSTRUCTION SPECIFICATIONS:

22 11 13 – General Plumbing Piping Systems Design Standard

END OF SECTION