

COMBINATION FIRE SMOKE DAMPER SCHEDULE

NO.	MANUFACTURER & MODEL NO.	SIZE (NO. OF X IN.)	INLET	OUTLET	SIZE	SERVICE	UNIT	LEAKAGE CLASS	TEMP. RATING	FIRE RATING	ACTUATOR TYPE	REMARKS	
FSD 11	RIEKEN FSD36-COU	22"x22"	22"x22"	22"x22"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 12	RIEKEN FSD36-COU	16"x16"	16"x16"	16"x16"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 13	RIEKEN FSD36-FA	36"x24"	36"x24"	36"x24"	6"	TRANSFER ROOM	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS. ACCESSIBLE THROUGH GRILLE.
FSD 14	RIEKEN FSD36-FA	36"x24"	36"x24"	36"x24"	6"	TRANSFER ROOM	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS. ACCESSIBLE THROUGH GRILLE.
FSD 15	RIEKEN FSD36-FA	14"x8"	14"x8"	14"x8"	6"	F.I.T.O.	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS. ACCESSIBLE THROUGH GRILLE.
FSD 16	RIEKEN FSD36-FA	14"x8"	14"x8"	14"x8"	6"	F.I.T.O.	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS. ACCESSIBLE THROUGH GRILLE.
FSD 17	RIEKEN FSD36-COU	44"x24"	44"x24"	44"x24"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 18	RIEKEN FSD36-C	6"x8"	6"x8"	6"x8"	6"	CORRIDOR	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS. INTERNALLY FOAMED ACTUATOR ACCESSIBLE THROUGH GRILLE.
FSD 19	RIEKEN FSD36	60"x20"	60"x20"	60"x20"	6"	CLASSROOM	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 20	RIEKEN FSD36	30"x20"	30"x20"	30"x20"	6"	CLASSROOM	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 21	RIEKEN FSD36	44"x20"	44"x20"	44"x20"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 22	RIEKEN FSD36	44"x20"	44"x20"	44"x20"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 23	RIEKEN FSD36	44"x24"	44"x24"	44"x24"	6"	EXHAUST FAN	AHU-2	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 24	RIEKEN FSD36	44"x24"	44"x24"	44"x24"	6"	EXHAUST FAN	AHU-2	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 25	RIEKEN FSD36	17"x20"	17"x20"	17"x20"	6"	DIBENSARY	AHU-2	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 26	RIEKEN FSD36	10"x10"	8"x8"	8"x8"	6"	DIBENSARY	AHU-2	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 27	RIEKEN FSD36	44"x16"	44"x16"	44"x16"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 28	RIEKEN FSD36	44"x16"	44"x16"	44"x16"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 29	RIEKEN FSD36	44"x16"	44"x16"	44"x16"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 30	RIEKEN FSD36	44"x16"	44"x16"	44"x16"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 31	RIEKEN FSD36	44"x16"	44"x16"	44"x16"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 32	RIEKEN FSD36	44"x16"	44"x16"	44"x16"	6"	EXHAUST FAN	AHU-1	1	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 33	RIEKEN FSD36	10"x10"	8"x8"	8"x8"	6"	ASSISTING STORAGE	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 34	RIEKEN FSD36	10"x10"	8"x8"	8"x8"	6"	ASSISTING STORAGE	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 35	RIEKEN FSD36	10"x10"	8"x8"	8"x8"	6"	ASSISTING STORAGE	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 36	RIEKEN FSD36	10"x10"	8"x8"	8"x8"	6"	ASSISTING STORAGE	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 37	RIEKEN FSD36	10"x10"	8"x8"	8"x8"	6"	ASSISTING STORAGE	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 38	RIEKEN FSD36	10"x10"	8"x8"	8"x8"	6"	ASSISTING STORAGE	AHU-1	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 39	RIEKEN FSD36-FA	14"x8"	14"x8"	14"x8"	6"	ELEVATOR	AHU-2	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 40	RIEKEN FSD36-FA	14"x8"	14"x8"	14"x8"	6"	ELEVATOR	AHU-2	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 41	RIEKEN FSD36-FA	14"x8"	14"x8"	14"x8"	6"	ELEVATOR	AHU-2	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 42	RIEKEN FSD36-FA	14"x8"	14"x8"	14"x8"	6"	ELEVATOR	AHU-2	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 43	RIEKEN FSD36-FA	14"x8"	14"x8"	14"x8"	6"	ELEVATOR	AHU-2	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 44	RIEKEN FSD36-FA	14"x8"	14"x8"	14"x8"	6"	ELEVATOR	AHU-2	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.
FSD 45	RIEKEN FSD36-FA	14"x8"	14"x8"	14"x8"	6"	ELEVATOR	AHU-2	2	350°F	1 1/2 HOURS	ELEC.	NC	BY-V-60Hz ACTUATOR UL 555 AND UL 555S LISTINGS.

SOUND ATTENUATOR SCHEDULE

NO.	MANUFACTURER & MODEL NO.	SIZE (NO. OF X IN.)	SERVICE / (HORIZONTAL)	CH	SIZE (NO. OF X IN.)	SERVICE / (HORIZONTAL)	CH	SIZE (NO. OF X IN.)	SERVICE / (HORIZONTAL)	CH	SIZE (NO. OF X IN.)	SERVICE / (HORIZONTAL)	CH
ST 1	LAC SLP5	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000
ST 2	LAC SLP5	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000
ST 3	LAC SLP5	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000
ST 4	LAC SLP5	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000	16"x16"	36"x24"	45000

McCarthy Building Companies, Inc.
 343 Sanson Street, 14th Floor
 San Francisco, California 94104
 P 415 397-5999
 F 415 397-5999

IDENTIFICATION STAMP
 DIVISION OF THE STATE
 APPL. ARCHITECT
 ACC. FLS. SS
 DATE

WESTERN ALLIED MECHANICAL INC.
 MECHANICAL CONTRACTORS
 1840 COMPTON ST. #200
 SAN FRANCISCO, CA 94115
 (415) 397-5454 FAX
 (415) 397-5454 TEL
 WWW.WESTERNALLIED.COM
 EOE M/F/V/H/O

The design is the exclusive property of Western Allied Mechanical, Inc. The drawings and specifications are to be used only for the project and not for any other project. Western Allied Mechanical, Inc. reserves the right to modify the drawings and specifications without notice. The contractor shall be responsible for obtaining all necessary permits and licenses. The contractor shall be responsible for obtaining all necessary approvals from the appropriate authorities. The contractor shall be responsible for obtaining all necessary approvals from the appropriate authorities. The contractor shall be responsible for obtaining all necessary approvals from the appropriate authorities.

College of San Mateo Building 5N
 DSA Submittal
 San Mateo, CA
 Developed for College of San Mateo

Revision Description Date

11/05/1
 Date: June 13, 2008
 Drawn by: RJ
 Checked by: LV
 Scale: SEE DRAWING

SCHEDULES
MO-03