



GENERAL NOTES  
 1. This sheet is part of a set and is not to be used alone.  
 2. This sheet is not to be used for construction unless the architect's stamp and signature appear on the drawings and the status box indicates drawings have been released for construction.  
 3. These plans and prints thereof, as instruments of service, are owned by the architect and are for use on this project only. Reproduction and/or distribution without the prior written consent of the architect is forbidden.  
 4. Copyright Bunton Clifford Associates, 2008

REMARKS	DATE
ADDITIONAL NO. 1	08/18/08
ADDITIONAL NO. 2	11/08/08

DRAWING STATUS	DATE
OS/PLAN CHECK	08/28/08
OS/BACK CHECK	01/22/09
BIDDING	09/18/09
CONSTRUCTION	

FILE NO. 41-C1  
 IDENTIFICATION STAMP  
 DIV. OF THE STATE ARCHITECT  
 01-110074  
 AC: FLS: SS:  
 DATE: \_\_\_\_\_

**BUILDINGS 5 & 6 RENOVATIONS**

San Mateo County Community College District

APPROVED  
 DIV. OF THE STATE ARCHITECT  
 AC: FLS: SS: 5  
 APPL. NO. 16074 DATE 5/24/10

**CAÑADA COLLEGE**  
 4200 Farm Hill Boulevard  
 Redwood City, CA 94061

**SITE DETAILS**

**26 WALL CAP** 3" = 1'-0"

02\_CONST\_02

**21 CONCRETE PAVING** 1" = 1'-0"

03\_COMPV\_01

**16 (E) TERRACE RAILING** 1" = 1'-0"

05\_MTLR\_16

**11 GUARD RAIL DETAIL** 3" = 1'-0"

05\_MTLR\_22

**6 GUARD RAIL DETAIL** 3" = 1'-0"

05\_MTLR\_15

**1 STAIR SECTION** 1-1/2" = 1'-0"

03\_CNSTR\_14

**27 WALL CAP AT STAIRS** 3" = 1'-0"

02\_CONST\_03

**22 TYP. CONCRETE JOINTS** 1/2" = 1'-0"

03\_COMPV\_02

**17 NOSING • (E) STAIR** 6" = 1'-0"

05\_STRNS\_01

**12 WALL SEAT** 3" = 1'-0"

02\_CONST\_01

**7 STAIR SECTION** 1/4" = 1'-0"

03\_CNSTR\_11

**23 ELEVATOR ROUTE SIGN** 1" = 1'-0"

02\_SIGN\_01

**13 WATERSTOPS AT FTGS.** 1/2" = 1'-0"

03\_CNSTR\_01

**8 GUARD RAIL DETAIL** 3" = 1'-0"

05\_MTLR\_22

**3 TOP LANDING** 1/2" = 1'-0"

05\_MTLR\_14

**24 TRUNCATED DOMES** 3" = 1'-0"

02\_CONST\_04

**19 METAL GATE** 1" = 1'-0"

05\_MTLR\_21

**14 RAMP SECTION** 1/4" = 1'-0"

02\_CONRP\_14

**9 STAIR SECTION** 1/4" = 1'-0"

02\_CONRP\_16

**4 GUARDRAIL DETAIL** 1/2" = 1'-0"

03\_CNSTR\_13

**25 CONCRETE COLUMN** 1" = 1'-0"

02\_CONST\_04

**20 TYP. RAMP GUARDRAIL** 3/4" = 1'-0"

05\_MTLR\_21

**15 TYP. RAMP HANDRAIL** 3/4" = 1'-0"

02\_CONRP\_11

**10 ENLARGED RAMP PLAN** 1/8" = 1'-0"

02\_RMPLN\_12

**5 BOTTOM LANDING** 1" = 1'-0"

03\_CNSTR\_13

172. Detail 20/A10.21 shows a trail guard rail at ramp. However detail 15/A10.21 does not show 7 rails at the guard rail. Please clarify.  
 Response: Detail 20 shows 7 horizontal rails at the guardrail with an additional handrail on the ramp side of the railing. Detail 15 shows the code-required handrail extension at the end of the ramp. Please note the guardrail is not extended, just the handrail.