


DOOR DETAIL NOTES:

1. SECURITY DOOR DETAILS DO NOT ACCOUNT FOR ITEMS SUCH AS TRANSOMS OR THE ABSENCE OF ACCESSIBLE CEILING ABOVE DOORS. THOROUGHLY REVIEW DOOR SCHEDULE, DOOR TYPES, AND HARDWARE SCHEDULE PRIOR TO PATHWAYS ROUGH-IN TO SECURITY DOOR FURNITURE AS SHOWN.
2. ALL DEVICE CABLE SHALL ROUTE TO SECURITY EQUIPMENT HUB(S) SPLICE FREE.
3. INSTALL 1/2" C BETWEEN JUNCTION BOXES AND DEVICES, UON.
4. VIEW OF DOORS ALWAYS FROM THE PROTECTED SIDE, UON.
5. JUNCTION BOXES ARE 4" SQ. X 2-1/8" D. UON.
6. DASHED SYMBOLS INDICATE DEVICES ON THE OPPOSITE SIDE OF THE WALL.
7. ALL CONTACTS SHALL BE RECESSED MOUNTED DOUBLE POLE DOUBLE THROW. CONNECT ACCORDING TO DOOR SEQUENCE OF OPERATIONS.
8. FLUSH MOUNT JUNCTION BOXES INSTALLED BELOW THE CEILING LINE.
9. CONCEAL CONDUIT MOUNTED BELOW THE CEILING LINE IN THE WALLS.
10. CONDUIT AND JUNCTION BOXES ARE NEW, UON.
11. INSTALL REQUEST TO EXIT DEVICES ON PROTECTED SIDE OF DOOR UON.
12. FIRE RATED DOORS AND FRAMES MUST BE FACTORY FABRICATED FOR SECURITY DEVICES INCLUDING LOCK WIRE PATHWAY, 1" DOOR CONTACTS, AND ACCESS HOLE BEHIND ELECTRIC TRANSFER HINGE. COORDINATE LOCATIONS AND SIZES WITH DEVICE MANUFACTURERS INSTALLATION TEMPLATES.
13. LOCATE ALL JUNCTION BOXES AND LOCAL POWER SUPPLIES ABOVE ACCESSIBLE CEILING GRID ON SECURE SIDE OF PROTECTED DOOR.

NetVersant
 47811 WARM SPRINGS BLVD.
 FREMONT, CA 94539
 OFFICE: 510.771.1200
 FAX: 510.252.0109



1 CARD READER PAIR ADA ENTRANCE W / PS
 SCALE: N.T.S.

2 CARD READER PAIR W / PS
 SCALE: N.T.S.

3 MONITORED SINGLE DOOR NO REX
 SCALE: N.T.S.

4 CARD READER PAIR ADA ENTRANCE W/KEYPAD & PS
 SCALE: N.T.S.

5 CARD READER SINGLE LOCKSET
 SCALE: N.T.S.

6 CARD READER / PANIC / NO PS
 SCALE: N.T.S.

ISSUANCE:
AS-BUILT DRAWINGS

PROPRIETARY INFORMATION
 NO PART OF THIS DOCUMENT MAY BE COPIED, REPRODUCED
 OR TRANSMITTED IN ANY FORM OR BY ANY MEANS WITHOUT
 PRIOR WRITTEN CONSENT OF NETVERSANT.

REVISIONS

NO.	DATE	DESCRIPTION
1	3/19/09	REVISE FOR AS BUILTS-ML

PROJECT:
 CANADA COLLEGE
 BUILDING # 8 PHASE 2
 REVOLUTION PROJECT
 4200 FARM HILL BLVD.
 REDWOOD CITY, CA 94061

SHEET TITLE:
 SECURITY SYSTEM
 DOOR DETAILS

DATE: 8/25/08
 DRAWN BY: BCH/JJA
 CHECKED BY: JLAMANTIA
 SCALE: AS NOTED
 JOB NO.: 109802306F25

SHEET NUMBER
SEC.5.01