

BUILDING 17 OVERALL FLOOR PLANS

SCALE: |" = 40'-0"

SHEET NOTES

- I. REMOVE ALL EQUIPMENT AND DUCTWORK IN ITS ENTIRETY.
- 2. REMOVE (E) CONTROLS IN THEIR ENTIRETY. ALL (E) PNEUMATIC CONTROL SYSTEM TUBING, HARDWARE AND ACCESSORIES ARE TO BE REMOVED IN THEIR ENTIRETY. (E) DDC CONTROLLERS AND WIRING MAY BE REUSED PROVIDING HARDWARE IS COMPATIBLE WITH NEW SYSTEM BEING INSTALLED.
- 3. (E) HEATING HOT WATER SUPPLY AND RETURN PIPING UP FROM BELOWGRADE. REMOVE (E) PIPING RISERS AND ALL DOWNSTREAM PIPING. LEAVE (E) STUBOUTS IN PLACE FOR CONNECTION OF NEW PIPING.
- 4. REMOVE ALL (E) HEATING HOT WATER PIPING AND ALL ASSOCIATED HANGERS AND ACCESSORIES.
- 5. AN EXISTING AIR COMPRESSOR THAT IS PART OF THE PLUMBING SYSTEMS PROVIDES COMPRESSED AIR TO BENCHES LOCATED IN THE CLASSROOMS. THIS AIR COMPRESSOR IS NOT TO BE DISTURBED. VERIFY EXACT LOCATION IN FIELD.





McCracken & Woodman, Inc. 355 Grand Ave. Oakland, CA 94610

Tel: (510) 763-4891 Fax: (510) 763-0619



CAÑADA COLLEGE


BUILDING 16, 17, 18 RENOVATION

SMCCCD 3401 CSM Drive San Mateo, CA 94402 Cañada College 4200 FarmHills Blvd. Redwood City, CA 94061

SHEET TITLE
BUILDING 17
MECHANICAL
FIRST FLOOR
DEMOLITION PLAN


REVISIONS NO. DATE DESCRIPTION 08/11/06 ADDENDUM NO. 1
BLDG 17 MODERNIZATION
2 02/01/07 RECORD SET

JP



DATE DRAWN CHECKED SCALE

BC 1/8" = 1'-0" N&T JOB NO.: SHEET NUMBER M1.21



RECORD DRAWING District Contract #

DATE: 02-01-07