


2)ROOM 2108 - FIRE ALARM PLAN

(E)JAN [2116]

G

SHEET NOTES

PROVIDE TOGGLE SWITCH WITH PILOT LIGHT FOR CONTROL OF POWER TO QUAD RECEPTACLE. ALL DEVICES MOUNTED AT + 48" AFF. PROVIDE SINGLE COVERPLATE FOR RECEPTACLE AND SWITCH. REFER TO SPECIFCATIONS.



PROVIDE (2) 4" CONDUIT SLEEVES. VERIFY EXACT LOCATION WITH TELECOM DRAWINGS.

- PROVIDE (1) 3/4" C. FROM PROJECTOR TO BUILDING MDF IN MECH/ELEC ROOM.
- PROVIDE BRACING AS REQUIRED FOR SUPPORT OF PANELBOARD PER DETAIL 1, SHEET E6.01.


SKYLINE COLLEGE **TCOM CLASSROOM RENOVATION BUILDING 2**




SAN MATEO COUNTY 3401 CSM DRUVE SAN MATEO CA 94402


> STEINBERG ARCHITECTS 60 Pierce Avenue San Jose CA 95110







DSA BACKCHECK



STEINBERG ARCHITECTS

EF1.3