

*2005 Nonresidential Energy Standards Compliance
(Title 24, Part 6, Ch. 1)*

Envelope Mandatory Measures

- Installed Insulating Material** shall have been certified by the manufacturer to comply with the California Quality Standards for insulating material.
- All Insulating Materials** shall be installed in compliance with the flame spread rating and smoke density requirements of Sections 2602 and 707 of the UBC.
- All Exterior Joints** and openings in the building envelope that are observable sources of air leakage shall be caulked, gasketed, weather-stripped or otherwise sealed.
- Site Constructed Doors, Windows and Skylights** shall be caulked between the unit and the building, and shall be weather-stripped (except for unframed glass doors and fire doors).
- Manufactured Doors and Windows** installed shall have air infiltration rates certified by the manufacturer per §116(a)1. Manufactured fenestration products must be labeled for U-factor according to NFRC procedures.
- Demising Wall Insulation** (R-13) shall be installed in all opaque portions of framed walls (except doors).