

CERTIFICATE OF COMPLIANCE

(Page 4 of 4)

LTG-1C

Project Name: College of San Mateo Building 34	Date: November 22, 2010
---	----------------------------

Conditioned and Unconditioned Space. Lighting must not be combined for compliance.

Indoor Lighting Power for Conditioned Spaces			Indoor Lighting Power for Unconditioned Spaces		
Installed Lighting (from Conditioned LTG-1C Page 2)	Watts	3,584	Installed Lighting (from Unconditioned LTG-1C Page 2)	Watts	
	Lighting Control Credit Conditioned Spaces (from LTG-2C)	-		0	Lighting Control Credit Unconditioned Spaces (from LTG-2C)
Adjusted Installed Lighting Power	=	3,584	Adjusted Installed Lighting Power	=	
Complies if Installed ≤ Allowed ↑↓			Complies if Installed ≤ Allowed ↑↓		
Allowed Lighting Power Conditioned Spaces (from LTG-3C)		10,136	Allowed Lighting Power Unconditioned Spaces (from LTG-3C)		

Required Acceptance Tests

Designer:

*This form is to be used by the designer and attached to the plans. Listed below is the acceptance test for the Lighting System, LTG-2A. The designer is required to check the acceptance tests and list all control devices serving the building or space shall be certified as meeting the Acceptance Requirements for Code Compliance. If all the lighting system or control of a certain type requires a test, list the different lighting and the number of systems. The NA7 Section in the Appendix of the Nonresidential Reference Appendices Manual describes the test. Since this form will be part of the plans, completion of this section will allow the responsible party to budget for the scope of work appropriately. **Forms can be grouped by type of Luminaire controlled.***

Enforcement Agency:

***Systems Acceptance.** Before Occupancy Permit is granted for a newly constructed building or space or whenever a new lighting system with controls is installed in the building or space shall be certified as meeting the Acceptance Requirements. The LTG-2A form is not considered a complete form and is not to be accepted by the enforcement agency unless the boxes are checked and/or filled and signed. In addition, a Certificate of Acceptance forms shall be submitted to the enforcement agency that certifies plans, specifications, installation certificates, and operating and maintenance information meet the requirements of §10-103(b) of Title 24 Part 6. The field inspector must receive the properly filled out and signed forms before the building can receive final occupancy. A copy of the LTG-2A for each different lighting luminaire control(s) must be provided to the owner of the building for their records.*

Luminaires Controlled				LTG-2A
Equipment Requiring Testing	Description	Number of like Controls	Location	Controls and Sensors and Automatic Daylighting Controls Acceptance
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>
				<input type="checkbox"/>