


SECURE FAN TO ROOF -AT EACH CORNER

3/8"ø HILTI KB TZ

1. BRANCH DUCT SIZE TO MATCH UNIT INLET CONNECTION. FOR BRANCH DUCTS OVER SIX FEET IN LENGTH, INCREASE BRANCH DUCT ONE SIZE AND PROVIDE TRANSITION IMMEDIATELY UPSTREAM OF MINIMUM STRAIGHT DUCT RUN.

2. MINIMUM 5'-0" LONG LINED PLENUM EQUAL TO TERMINAL BOX OUTLET SIZE.

3. MINIMUM STRAIGHT DUCT RUN: DUCT DIA MIN STRAIGHT RUN



2 TRAPEZE PIPE HANGER DETAIL

-1/2" # HILTI KB TZ 2" EMBED, ESR

DISTANCE MIN OF 5". SEE NOTE 2

(E) CONCRETE

- THREADED COUPLER

THREADED ROD

ROD HANGER

P1000T


WHERE

STIFFENER

1917, SPECIAL INSPECTION REQUIRED

ANCHOR SPACING MIN OF 6" AND EDGE

P_{max}=200 LBS



1. COORDINATE SIZE AND LOCATION OF ROOF PENETRATION WITH STRUCTURAL ENGINEER AND GENERAL

2. SEE 16/A10.7 FOR DETAILS NOT SHOWN OR NOTED.

CONTRACTOR.

THIS HANGER IS FOR

DUCTS 24" DIA. &

SMALLER

3/8" BOLT, NUT &


STAR WASHER -


3. SCAN FOR REBAR PRIOR TO DRILLING HOLES FOR ANCHORS. DO NOT CUT OR DAMAGE REBAR. SEE GENERAL NOTES ON SHEET SO.1.


3 ROOF EXHAUST FAN

1. REFER TO SPECIFICATIONS FOR HANGER SPACINGS.


- 2. ATTACHMENTS TO OVERHEAD STRUCTURE SHALL BE MADE IN ACCORDANCE WITH STRUCTURAL ENGINEERS REQUIREMENTS AND WEIGHT LIMITATIONS. ALL ATTACHMENT METHODS TO STRUCTURE SHALL BE SUBMITTED TO ARCHITECT AND STRUCTURAL ENGINEER FOR REVIEW. 3. PROVIDE SWAY & SEISMIC BRACING PER SMACNA SEISMIC GUIDELINES AND THE LATEST EDITION OF CALIFORNIA BUILDING CODE. CONTRACTOR SHALL INDICATE LOCATIONS OF SEISMIC BRACING ON THE SHOP DRAWING SUBMITTALS.
- 4. HANGER MATERIAL SUPPORTING FLEXIBLE DUCT SHALL IN NO CASE BE LESS THAN 1 1/2 INCHES WIDE. FLEXIBLE DUCT SHALL BE SUPPORTED PER MANUFACTURER'S RECOMMENDED MATERIALS, BUT AT NO GREATER DISTANCE THAN 4 FEET MAX. PERMISSIBLE SAG IS MAX. 1/2 INCHES PER FOOT OF SPACING BETWEEN SUPPORTS.
- 5. REFER TO STRUCTURAL DRAWINGS, SO.1.








6 CONNECTION TO EXISTING STRUCTURE



- 1. ATTACHMENT TO OVERHEAD STRUCTURE SHALL BE MADE IN ACCORDANCE WITH STRUCTURAL ENGINEERS REQUIREMENTS AND WEIGHT LIMITATION PER
- 2. PROVIDE SWAY & SEISMIC BRACING PER MASON SEISMIC GUIDELINES, INCLUDING ALL ANGLE, LONGITUDINAL AND TRANVSVERSE.
- 3. SEE 2/-- FOR BRACE TOP CONNECTION.
- 4. OMIT BRACING IF PIPE HANGER ROD LENGHT IS LESS OR EQUAL 12".

8 PIPE HANGER DETAILS



1 VAV TERMINAL UNIT DETAIL

HANGER STRAP SECURE TO (E)STRUCTURE AS REQ'D

PROVIDE 2 ANGLE CLIPS ON OPPOSITE SIDES OF DIFFUSER SCREW TO T-BAR 11111 - PERFORATED FACE SUSPENDED CEILING LAY-IN T-BAR CEILING DIFFUSER

5 CEILING DIFFUSER CONNECTION DETAIL

4 SPLIT SYSTEM MOUNTING DETAIL

SIDE VIEW

CAÑADA COLLEGE 4200 Farm Hill Boulevard Redwood City, CA 94061

architecture

planning

interiors

Bunton Clifford Associates, Inc.

210 Hammond Ave.

Fremont, California 94539

[T] 510.445.1000

[F] 510.445.1005

www.BCAincOnline.com

= INTERFACE

ENGINEER

PROJECT 2007-0731

717 Market Street

FAX 415.489.7289

San Francisco, CA 94103 TEL 415.489.7240

ARCHITECT

www.interfaceengineering.com

This sheet is part of a set and is not to be used alone.

These plans and prints thereof, as instruments of service are owned by the architect and are for use on this project

only. Reproduction and/or distribution without the prior

written consent of the architect is forbidden.

4. Copyright Bunton Clifford Associates, 2007

O DSA PLAN CHECK

O DSA BACK CHECK

E O CONSTRUCTION

BIDDING (BID #86593)

FILE NO. 41-C1

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT

01- 110074

BUILDINGS 5 & 6

RENOVATIONS

San Mateo County Community
College District

DSA BACK-CHECK

AC M FLS N SS Y

DATE MAR 1 9 2009

2. This sheet is not to be used for construction unless the architect's

stamp and signature appear on the drawings and the status box indicates drawings have been released for construction.

Suite 500

CONTACT Omar Hawit

MECHANICAL DETAILS

Drawing Number 01/22/09 M6.2 AS NOTED Project Number 07013

FILE: 0731M62.DWG - M62 | EDIT: 3/18/2009 11:53 AM BY ALANB | PLOT: 3/18/2009 11:53 AM BY ALAN BLUI

PROVIDED BY

UNIT MANUFACTURER

-SUPPORT ANGLE IN UNIT

PROVIDED BY MANUFACTURER

SECURE MOUNTING BRACKET

TO METAL STUDS

REFRIGERANT, DRAIN, POWER

AND SIGNAL LINES.

1. FOR DRAIN CONNECTION, REFER TO PLUMBING DRAWINGS.

FAN COIL UNIT MOUNTING DETAIL ON WALL