


**FOUNDATION AND FLOOR FRAMING PLAN NOTES:**

1. FOR GENERAL NOTES AND TYPICAL STRUCTURAL DETAILS NOT SHOWN HEREIN SEE SHEETS S1.1, S1.2, S1.3, S1.4, S1.5, S1.6, AND S1.7.
2. SEE ARCHITECTURAL, MECHANICAL, PLUMBING, AND ELECTRICAL DRAWINGS FOR PERTINENT INFORMATION NOT SHOWN HEREIN. VERIFY ALL ITEMS WITH RESPECTIVE TRADES PRIOR TO POURING CONCRETE FOOTINGS.
3. ALL GRIDS AND DIMENSIONS ARE TO FACE OF STUD WALL AS SHOWN OR NOTED ON DRAWINGS, UNLESS OTHERWISE NOTED.
4. CENTERLINE OF FOOTING SHALL COINCIDE WITH CENTERLINE OF STUD WALL ABOVE, UNLESS OTHERWISE SHOWN OR NOTED.
5. F.O.S. DENOTES FACE OF STUD WALL.  
E.O.C. DENOTES FACE OF EXTERIOR CONCRETE CURB.
6. SLAB-ON-GRADE SHALL BEAR A MINIMUM OF 2" ON THE FOOTING WALL, UNLESS OTHERWISE NOTED.
7. SEE ARCHITECTURAL, MECHANICAL, AND ELECTRICAL DRAWINGS FOR OPENINGS IN WALLS AND LOCATIONS OF ALL CURBS, SLOPES, AND DRAINS.
8. C.J. DENOTES JOINT IN CONCRETE SLAB. SEE DETAILS ON SHEET S1.5.
9. ELEVATION OF BOTTOM OF FOOTINGS SHALL BE -3'-0" MIN. AND SHALL BE AT LEAST 18" BELOW ADJACENT GRADE, UNLESS SHOWN OTHERWISE.
10. ALL FOOTINGS SHALL BE 1'-6" WIDE, TYP., U.O.N.
11. PROVIDE 5/8" SILL BOLTS (S.B.) AT 48" O.C. TYP., U.O.N.
12. ALL EXTERIOR WALLS SHALL BE SHEATHED W/ 1/2" PLYWOOD, TYP., U.O.N.
13. ALL STUD WALLS SHALL BE 2x6 @ 16" O.C., UNLESS OTHERWISE NOTED.
14. INDICATES 1/2" P.W. ON ONE SIDE OF STUD WALL FOR FULL LENGTH OF WALL. SEE PLAN FOR LOCATIONS. SEE DET. 8/S1.6 FOR PLYWOOD SCHEDULE.
15. INDICATES 1/2" P.W. ON BOTH SIDES OF STUD WALL FOR FULL LENGTH OF WALL. SEE PLAN FOR LOCATIONS. DO NOT LOCATE PLYWOOD JOINTS ON SAME STUD. SEE DET. FOR PLYWOOD SCHEDULE.
16. INDICATES SIMPSON HOLDOWN WITH SILL BOLTS @ REQUIRED SPACING BETWEEN POSTS. ALL HOLDOWNS REQUIRE 6x8 POST IN 2x8 WALLS, 6x6 POST IN 2x6 WALLS, U.O.N.
17. INDICATES 6x6 POST, TYP., U.O.N. FOR POSTS @ HOLDOWNS. SEE NOTE 18. CENTER POSTS UNDER BEAMS ABOVE, TYP., U.O.N.
18. INDICATES POST OR COLUMN BELOW. SEE NOTE 17.
19. INDICATES CONCRETE CURB @ INTERIOR STUD WALLS. S.A.D. FOR EXACT DIMENSIONS AND LOCATIONS, & SEE 9/S1.5.
20. SEE 5/S3.2 FOR L3X3X1/4 VERTICAL DETAIL.

**FOUNDATION AND GROUND FLOOR FRAMING PLAN**

1/8"=1'-0"



<b>REVISIONS:</b> (A) REVISION NUMBER (SEE THIS SHEET) NO. DATE REASON BY 10/2/01 ADD COLUMN #1			
<b>CONSULTANT:</b> <b>Degenkolb Engineers</b> 900 Frank H. Ogawa Plaza Suite 400 Oakland, CA 94612-2001 Phone: (925) 258-8634 Fax: (925) 258-9558			
<b>ARCHITECT:</b> <b>C IAN FICHI</b> <b>ARCHITECTURE · PLANNING</b> 30 ANNE COURT WALNUT CREEK, CA 94598 TEL: (925) 258-8634 FAX: (925) 258-8652			
<b>PROJECT:</b> <b>CHILD DEVELOPMENT CENTER</b> <b>CANADA COLLEGE</b>			
<b>STAMP:</b> APPROVED DIV OF THE STATE ARCHITECT AC BR FILS BH 98 12/1 APPL NO. 01-13129 DATE 2/6/01			
APPL NUMBER: KEY PLAN:			
AS-BUILTS			
SHEET TITLE: <b>FOUNDATION AND GROUND FLOOR FRAMING PLAN</b>			
DRAWN BY: JS	PROJECT NO.: 20024		
CHECKED BY: MAE/RT	DATE: 01-13-01		
APPL NO.: 201-000	SHEET: S21a		
DATA NO.: 201-000	NO.: 1		