


1 SECOND FLOOR POWER AND SIGNAL PLAN
1/8" = 1'-0"

- ⊠ CEILING 15'-0" FROM SCREEN. PROVIDE FOR TELECOM INTERFACE.
- ⊠ RECEPTACLE EVERY 2'-0" ON CENTERS.
- ⊠ ON TOP OF LAB BENCH. RUN CONDUIT REED RECEPTACLE. REFER TO LAB BENCH
- ⊠ ESS ACCESS POINT WIRING. REFER TO AND SIZE.
- ⊠ AFF FOR INSTRUCTIONAL PATHWAY. PROVIDE SPACE. REFER TO TELECOM DWGS. FOR EXACT
- ⊠ UB INTO ACCESSIBLE CEILING SPACE. REFER AND SIZE.
- ⊠ INGS FOR EXACT LOCATION AND SIZE.
- ⊠ TO THIRD FLOOR IT ROOM, 7316. REFER TO AND SIZE.

- ⊠ SURGICAL LIGHT PROVIDED BY OTHERS. PROVIDE JUNCTION BOXES FOR DISPLAY LIGHTS AND RELATED ACCESSORIES. COORDINATE EXACT POWER REQUIREMENTS PRIOR TO ROUGH-IN.
- ⊠ ALL 120V. CIRCUITS FOR MISC. RECEPTACLES, EQUIPMENT, ETC. SHALL BE CONNECTED FROM PANEL "7R2B" U.O.N.
- ⊠ ALL 120V. CIRCUITS FOR MISC. RECEPTACLES, EQUIPMENT, ETC. SHALL BE CONNECTED FROM PANEL "7R2A" U.O.N.
- ⊠ ALL 480V/3Ø CIRCUITS FOR MECHANICAL EQUIPMENTS ETC. SHALL BE CONNECTED FROM "MCCB".
- ⊠ IN ADDITION TO REQUIRED BRANCH CIRCUIT CONDUITS, PROVIDE 4-X 1/2" C.O.W/ PULL STRING TO ACCESSIBLE CEILING. ALSO SEE 1/EE6.02.
- ⊠ ALTERNATE LOCATIONS OF EF/7-1 SWITCHES. SEE DWG. E3.04 SHEET NOTE 5.
- ⊠ ALTERNATE LOCATIONS OF EF/7-4 SWITCHES. SEE DWG. E3.04 SHEET NOTE 4.
- ⊠ JUNCTION BOX FOR 120V POWER TO FUMEHOOD AUXILIARY DEVICES (LIGHTING, RECEPTACLES).

- ⊠ WIREMOLD PLUGMOLD WITH DUPLEX RECEPTACLE MOUNTED EVERY 2'-0" ON CENTERS. MOUNT PLUGMOLD TO UNISTRUT SYSTEM. PROVIDE DUPLEX RECEPTACLE MOUNTED AT END OF S.O. CORD AT ONE END OF PLUGMOLD AS SHOWN.
- ⊠ JUNCTION BOX FOR 120V POWER TO STERILIZER CONTROLS. VERIFY EXACT POWER CONNECTIONS PRIOR TO ROUGH-IN.



ALFATECH CONSULTANTS
1000 Project No. 2007100
DATE 3-12-2007

DESIGNED BY	DSA BACK CHECK	02.27.07
DRAWN BY	DSA SUBMITTA	11.02.06
CHECKED BY		10.13.06
DATE		06.12.06
PERCENT COMPLETE		40% PROGRESS

STEINBERG ARCHITECTS
PROJECT NO. 06015
DATE 02.27.07
DRAWN BY MAMP
CHECKED BY VE
SCALE 1/8" = 1'-0"

E3.02

