

(2) 4°C UP TO THIRD FLOOR IT ROOM, 7316. REFER TO TELECOM DRAWINGS FOR EXACT LOCATION AND SIZE.

CIRCUIT SHOWN IS FOR POWER TO LOCK POWER SUPPLY. REFER TO SECURITY DRAWING, SY4.01 FOR EXACT CIRCUIT CONFIGURATION.

(2) 4°C UP TO SECOND FLOOR CEILING SPACE. REFER TO TELECOM DRAWINGS FOR EXACT LOCATION AND SIZE.

9 TELECOM GROUND BUSBAR.

SKYLINE COLLEGE




STEINBERG ARCHITECTS 60 Pierce Avenue San Jose CA 95110

IN ADDITION TO REQUIRED BRANCH CIRCUIT CONDUITS, PROVIDE 4-34"C.O. W/FULL STRING TO ACCESSIBLE CEILING. ALSO SEE 1/E6.02.

QUAD RECEPTACLE FOR POWER TO PORTABLE ASSISTIVE LISTENING DEVICES.

CIRCUIT SHOWN IS FOR POWER TO QUAD RECEPTACLE, LOW VOLTAGE TRANSFORMER, AND DEVICE POWER SUPPLY. REFER TO SECURITY DRAWING, SY4.01 FOR CIRCUIT CONFIGURATION.



STEINBERGARCH'ITECTS

project no: 06015 date: 02.27.07
drawn by: MAMP checked by: VB scale: 1/8°= 1'-0° 0 6

FIRST FLOOR POWER AND SIGNAL PLAN E3.01